

## Blow-out times for automatic fuses

Code:	Fuse	100% (A)	150% (A)	200% (A)
89137	40A	30-60S	15-30S	5-10S
89138	60A	30-60S	15-30S	5-10S
89139	80A	30-60S	10-20S	5-10S
89140	100A	30-60S	10-15S	5-10S
89141	150A	20-40S	10-15S	3-8S
89142	200A	15-30S	10-15S	2-5S
89143	250A	15-30S	10-15S	2-5S
89144	300A	15-20S	10-15S	2-5S

100% (A) – current according to the fuse

150% (A) – current 1,5 times higher than the fuse

200% (A) – current 2 times higher than the fuse

S - (seconds) time after the fuse blow out